





PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

<p>Item Descriptions</p> <p>Dimensions</p> <p>Model</p> <p>Material</p> <p>Country of Origin</p> <p>Manufacturer</p> <p>Supplier</p> <p>Contact Tel/Fax</p> <p>E-mail</p> <p>Website</p>	<p>GROHE (Germany) Angle stop valve 1/2 inch. x 3/8 inch</p> <p>L80 x W55 x H55 mm</p> <p>22037000</p> <p>Chrome Plated</p> <p>Italy</p> <p>GROHE Limited</p> <p>Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen</p> <p>(852) 2388-7171 / (852) 2710-8012</p> <p>acme@acmesanitary.com.hk</p> <p>www.acmesanitary.com.hk</p>	<p>Illustration/ Drawing</p>  
<p>Angle valve 1/2"</p> <p><u>Product Descriptions</u></p> <ul style="list-style-type: none"> · pre-roughened connection thread for easy sealing · wall connection 1/2" · outlet thread 3/8" · with length compensation · with compression nut Ø 10mm · water protected spindle shutoff, brass, · with grease chamber and double o-ring sealing · long connecting shaft · ergonomic metal handle · marking: neutral · metal push-on escutcheon Ø 55 mm · GROHE StarLight finish 		

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



水務署
Water Supplies Department

總部 Headquarters

灣仔告士打道七號入境事務大樓 48 樓

7 Gloucester Road, Wan Chai, Hong Kong



本署
Our ref.
來函編號
Your ref.

3321/2021 T/J(1355/2021)

電話
Tel. :
傳真
Fax. : 2824 0578

22 October 2021



Approval of "GROHE" Angle Valve (General Acceptance No. C20211170)

Your letter ref. WRC/2630 dated 30 August 2021 refers.

Having considered the test report ref. J26546 issued on 28 July 2021 by Nutek System (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Italy

Brand: Grohe

Details of Fitting: 1/2" x 3/8" Copper alloy angle valve

Model: 22037000

Body Markings: 

Expiry Date: 8 June 2026

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only