



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Germany) "Eurodisc Cosmopolitan" Single-lever sink mixer 1/2" ; nominated flow rate <b>4.4 L/min</b> in WELS <b>Grade 1</b> ; Registration No. TM 20-0197
Dimensions	L223 x W120 x H306 mm
Model	32259003
Finish	Chrome Plated
Country of origin	Germany
Manufacturer	GROHE Limited
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Illustration/ Drawing

- 
- 
- 
- 
- 

306

213

55°

55°

44

max.60

Ø51

Ø34

555


223

G<sup>3</sup>/<sub>8</sub>

120

150°

- |   |   |
|---|---|
| <ul style="list-style-type: none"> <li>· high spout</li> <li>· monobloc installation</li> <li>· <b>GROHE StarLight</b> chrome finish</li> <li>· <b>GROHE SilkMove</b> 35 mm ceramic cartridge</li> <li>· <b>GROHE Zero</b> separated inner water ways - lead and nickel free</li> </ul> | <ul style="list-style-type: none"> <li>· adjustable flow rate limiter</li> <li>· swivel tubular spout</li> <li>· selectable swivel area : 0° / 150°</li> <li>· mousseur</li> <li>· flexible connection hoses</li> <li>· GROHE QuickFix rapid installation system</li> </ul> |
|---|---|



\* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.):

TM 20-0197



### 自願參與用水效益標籤計劃 - 水龍頭 Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明

This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

- |                                |   |   |
|--------------------------------|---|---|
| 牌子 / Brand                     | : | Grohe   |
| 型號 / Model                     | : | 32259XX3 + 402748040                          |
| 種類 / Type                      | : | Mixing  |
| 原產地 / Country or Region Origin | : | Portugal (Mixer)<br>Germany (Flow Controller) |

XX - denotes colour variants

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	4.4	公升/分鐘 <i>litres/minute</i>

簽發日期：  
Date of Issue: 16 October 2020

水務署  
Water Supplies Department



水務署署長(葉哲奇代行)  
for Director of Water Supplies



水務署  
Water Supplies Department



總辦事處：入境事務大樓 48 樓  
48/F, Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (5) in WSD 3321/2020 T/J(384/2020)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.


27 July 2020



**Approval of "GROHE" Sink Mixer  
(General Acceptance No. C20200612)**

Your letter ref. WRC/2175 dated 16 April 2020 and subsequent submissions received by this department up to 8 July 2020 refer.

Having considered the test reports ref. J25220A and J24850-1 issued on 8 April 2020 and 3 July 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Grohe AG  
**Country of Origin:** Portugal  
**Brand:** Grohe  
**Details of Fitting:** 3/8" Single lever sink mixer with 1 no. of flexible hose  
**Model:** 32259XX3  
(where the digits "XX" denote the code of colour)  
**Body Markings:**   
**Expiry Date:** 2 March 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82   ] - without catalogue  
            ME/MC           ] - with soft copy only