



Acme Sanitary Ware Co Ltd



Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong
 Tel: 2388 7171 Fax: 2710 8012
 E-mail: acme@acmesanitary.com.hk
 Website: www.acmesanitaryware.com.hk



Pure Freude
an Wasser

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Germany) "Grohtherm 800" Thermostatic bath/shower mixer	Illustration/ Drawing
Dimensions	L304 x W168 x H70 mm	 
Model	34567000	
Finish	Chrome Plated	
Country of Origin	Portugal	
Manufacturer	GROHE Limited	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p>wall mounted GROHE StarLight chrome finish GROHE SafeStop at 38°C GROHE SafeStop Plus optional temperature limiter at 43°C included GROHE TurboStat compact cartridge with wax thermoelement integrated mixed water shut off automatic diverter: bath/shower volume handle with GROHE EcoButton (economy button with individually adjustable economy stop) ceramic headpart 1/2", 180° shower bottom outlet 1/2" mousseur built-in non return valves dirt strainers protected against backflow S-unions metal escutcheon min. recommended pressure 1.0 bar GROHE EcoJoy technology for less water and perfect flow</p>		

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



Department

道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(766/2020)
Our ref.
來函檔號 :
Your ref.


電話 :
Tel.
傳真 : 2824 0578
Fax.

7 October 2020

Approval of "GROHE" Thermostatic Mixer (General Acceptance No. C20200875)

Your letter ref. WRC/2249 dated 22 June 2020 and subsequent submissions received by this department up to 25 September 2020 refer.

Having considered the test report ref. J24999r2 issued on 17 September 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG
Country of Origin: Portugal
Brand: Grohe
Details of Fitting: 1/2" Thermostatic bath/shower mixer
Model: 34567XXX
(where the digits "XXX" denote the code of colour)
Body Markings: 
Expiry Date: 12 January 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only