

## Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong Tel: 2388 7171 Fax: 2710 8012 Email: acme@acmesanitarv.com.hk Since 1949 Website: www.acmesanitary.com.hk



PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

#### SANITARY WARE SPECIFICATION SHEET

Item Descriptions GROHE (Germany) "Eurosmart

Cosmopolitan T" Self-closing basin mixer

with mixing device and adjustable

temperature limiter; nominated flow rate 4.6 L/min in WELS Grade 1; Registration No.

TM 21-0275

Dimensions L105 x W64 x H127 mm

Model 36317000

Finish Chrome Plated

Manufacturer **GROHE Limited** 

Country of Origin Germany

Supplier Acme Sanitary Ware Co. Ltd

Mr. Eric Wong/ Mr. Don Yuen


Contact Tel/Fax (852) 2388-7171 / (852) 2710-8012

E-mail acme@acmesanitary.com.hk Website www.acmesanitary.com.hk


· Self-closing basin mixer with mixing

device and adjustable temperature limiter ·

- **GROHE StarLight** chrome finish
- 3 adjustable flow times: short medium ·
- long
- · (factory setting: short), approx. 7, 15, 30 sec
- (pressure dependent)
- pressure range 0.5 to 6 bar
- flexible connection hoses
- non-return valve
- dirt strainers







<sup>\*</sup> All information of the above is for the reference only. No prior notice is made if any changes.



### 自願參與用水效益標籤計劃 - 水龍頭 Voluntary Water Efficiency Labelling Scheme - Water Taps



This is to certify that

#### 將下列水龍頭在本計劃內註冊: has registered the following water tap under this scheme:

子 / Brand

/ Model

/ Type

原產地 / Country or Region Origin Grohe

36317XXX + 402717040

Mixing

Germany (Mixer & Flow Controller)

XXX - denotes the code of colour

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label

Water droplet(s)

用水效益级别

Water Efficiency Frade

with additional merit\*

耗水量

Water Consumption

4.6

公升/分鐘 litres/minute

\*with additional merit of "Automatic closing mechanism"

簽發日期:

12 November 2021

Date of Issue:

Water Supplies Department



水務署署長(尤孝賢代行) for Director of Water Supplies



本署檔號 Our ref. 來函檔號

Your ref.

: (4) in WSD 3321/2021 T/J(188/2021)

電話

Tel.

傳真 Fax.

2824 0578

18 May 2021



# Approval of "GROHE" Self Closing Mixer (General Acceptance No. C20210525)

Your letters ref. C-WSD/0697 and C-WSD/0762 dated 12 January 2021 and 22 April 2021 respectively refer.

Having considered the test report ref. J24773Ar1 issued on 7 January 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Grohe AG

Country of Origin:

Germany

Brand:

Grohe

**Details of Fitting:** 

3/8" Self closing basin mixer

Model:

36317XXX

(where the digits "XXX" denote the code of colour)

**Body Markings:** 

GROHE

**Expiry Date:** 

5 November 2024





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only