



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

<p>Item Descriptions</p> <p>Dimensions</p> <p>Model</p> <p>Material</p> <p>Manufacturer</p> <p>Source</p> <p>Contact Tel/Fax</p> <p>E-mail</p> <p>Website</p>	<p>EMCA (PRC) Ø32 x 750 x 900mm long horizontal wall to wall stainless steel 304 grab bar in satin finish ; GB 175-2007 ; capable of carrying a static loading test 150kg ; test report J23882 ; complied with Barrier Free Access 2008</p> <p>L900 x W750 x 32 diameter</p> <p>EM7014.013-900</p> <p>Stainless steel</p> <p>EMCA (PRC)</p> <p>Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen</p> <p>(852) 2388-7171 / (852) 2710-8012</p> <p>acme@acmesanitary.com.hk</p> <p>www.acmesanitary.com.hk</p>	<p style="text-align: center;">Illustration/ Drawin</p> <div style="text-align: right;"></div>
---	--	--

Note:

** All information of the above is for the reference only. No prior notice is made if any changes.*



Test Report

TITLE : Loading Test

OUR REFERENCE : J 23882

DESCRIPTION OF SAMPLE : L900 x W750 x 32 diameter aluminium grab bar

SAMPLE SUBMITTED BY : Acme Sanitary Ware Co., Ltd.
1/F, Acme Building,
22-28 Nanking Street
Yau Ma Tei, Kowloon
Hong Kong

COUNTRY OF ORIGIN : PRC

BRAND NAME : EMCA

MODEL : EM7014.013-900

METHOD OF TESTS : Loading test

PERIOD OF TESTS : 07 Mar., 2019

RESULTS: (apply only to the sample tested)

1. LOADING TEST

The sample was installed onto a concrete wall in its normal application (cement to GB 175-2007). A test load was applied to the mid point of the sample which was then examined for any signs of damage.

ID	Weight/ downward load (kg)	Test duration (min)	Break/failure/ deflection/crack
Sample	150	30	Nil

Remark: Pass

Date: 13 Mar., 2019

Authorized signature: _____

NG DICK TIK LUN
(Mechanical Engineer)

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for testing water supply fittings.