

Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong Tel: 2388 7171 Fax: 2710 8012 Email: acme@acmesanitary.com.hk Since 1949 Website: www.acmesanitary.com.hk



PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET Item Descriptions EMCA (PRC) Ø32 x 750mm long stainless Illustration/ Drawing steel 304 hinged support rail in satin finish; BS12:1978 & BS882:1973 capable of carrying a static loading test 150kg; test report J17176; complied with Barrier Free Access 2008 Dimensions 32mm dia x 750mm long Model EM7020.013 Finish Stainless Steel Manufacturer EMCA (PRC) Supplier Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen Contact Tel/Fax (852) 2388-7171 / (852) 2710-8012 E-mail acme@acmesanitary.com.hk Website www.acmesanitary.com.hk 750mm 300mm 290mm 配件: 爆炸螺丝M8

N.	Τ	4
1	1()	ıe:

^{*} All information of the above is for the reference only. No prior notice is made if any changes.

: Testing of rail

OUR REFERENCE : J 17176

DESCRIPTION OF SAMPLE : Ø32mm x 750mm Stainless steel swing up grab bar

SAMPLE SUBMITTED BY : Acme Sanitary Ware Co. Ltd.

1/F., Acme Building, 22 Nanking Street, Kowloon, Hong Kong

BRAND : EMCA

MODEL : EM7020.013

COUNTRY OF ORIGIN : China

TEST REQUIRED : Loading test

PERIOD OF TESTS : 6th August 2013

RESULTS: - (apply only to the sample tested)

LOAD TEST

The grab rail sample was installed onto a concrete wall made of concrete mix grade 30D10 (cement to BS12: 1978 and Aggregate to BS882: 1973).

A test load was applied vertically to the mid point of the rail which was then examined for any signs of damage.

	Test load (kg)	Duration (minute)	Visual damage (e.g. breakage, deformation, etc.)	Remark
Sample	150	5	No visual damage	Pass

Date: 26Nov 2013 Authorized signature:

Nutek System in a testing agency, approved to Water Authority and Government for Department, for

testing water supply fittings.

Sunny K.S. Wong

(Director)