







PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	American Standard (PRC) "Signature" Brass exposed bath and shower mixer in chrome finish	<p>Illustration/ Drawing</p>    
Dimensions	Refer to drawing	
Model	FFAS1711-609500BC0	
Material/Finish	Brass / Chrome Finish	
Manufacturer	American Standard (PRC)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p>FEATURES</p> <ul style="list-style-type: none"> · A grade brass, strong and durable · Grohe High quality ceramic valve for longer usage · Ceramic cartridge tested = 500,000 times · 2-way pull diverter for spout and shower · Neoperl aerator · Without shower kits · With normal packaging · Flow rate @ 0.1MPa: 8.5 L/min for spout · Flow rate @ 0.1MPa: 13.5L/min for shower outlet <p>SPECIFICATIONS</p> <ul style="list-style-type: none"> · Exposed Bath & Shower Mixer Faucet · 2-Hole Installation: lever handle (cold& hot) · Spout Reach: 178mm <p>FINISHES AVAILABILITY</p> <ul style="list-style-type: none"> · Chrome (-CP) 		



Note: Equivalent to CF-1711.609.50

* All information of the above is for the reference only. No prior notice is made if any changes.



總行
香港灣仔入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2020 T/J(239/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

5 May 2020



**Approval of "AMERICAN STANDARD" Bath/Shower Mixer
(General Acceptance No. C20200292)**

Your letter ref. WRC/2163 dated 11 March 2020 refers.

Having considered the test report ref. J24050 issued on 14 January 2020 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: American Standard
Country of Origin: the Mainland of China
Brand: American Standard
Details of Fitting: 1/2" Single lever bath and shower mixer
Model: FFAS1711-609500BC0
Body Markings: *American Standard*
Expiry Date: 8 May 2024



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only