



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

**SANITARY WARE SPECIFICATION SHEET**

Item Descriptions	American Standard (PRC) "Signature" Brass exposed bath and shower mixer in chrome finish; Nominal flow rate 16 L/min	<p align="center">Illustration/ Drawing</p>
Dimensions	Refer to drawing	
Model	FFAS1712-709500BC0	
Material/Finish	Brass / Chrome Finish	
Manufacturer	American Standard (PRC)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<b>FEATURES</b>		
<ul style="list-style-type: none"> <li>• A grade brass, strong and durable</li> <li>• Grohe High quality ceramic valve for longer usage</li> <li>• Ceramic cartridge tested = 500,000 times</li> <li>• Without shower kits</li> <li>• With normal packaging</li> <li>• Flow rate @ 0.1MPa: 16 L/min for shower outlet</li> </ul>		
<b>SPECIFICATIONS</b>		
<ul style="list-style-type: none"> <li>• Exposed Bath &amp; Shower Mixer Faucet</li> <li>• 2-Hole Installation: lever handle (cold &amp; hot)</li> </ul>		
<b>FINISHES AVAILABILITY</b>		
<ul style="list-style-type: none"> <li>• Chrome (-CP)</li> </ul>		

Note: Equivalent to CF-1712.709.50

\* All information of the above is for the reference only. No prior notice is made if any changes.



Department

二號入境事務大樓 48 樓

2 Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署編號 : (4) in WSD 3321/19 T/J(739/2019)  
Our ref.  
來函編號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

11 September 2019

### Approval of "AMERICAN STANDARD" Shower Mixer (General Acceptance No. C20190463)

Your letters ref. WRC/2095 and C-WSD/0527 dated 27 July 2019 and 23 August 2019 respectively refer.

Having considered the test report ref. J24049 issued on 17 June 2019 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** American Standard  
**Country of Origin:** the Mainland of China  
**Brand:** American Standard  
**Details of Fitting:** 1/2" Single lever shower mixer  
**Model:** FFAS1712-709500BC0  
**Body Markings:** *American Standard*  
**Expiry Date:** 5 May 2024



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHEUNG Yip-kui)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only