



Since 1949


Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong


Tel: 2388 7171 Fax: 2710 8012

Email: acme@acmesanitary.com.hk

Website: www.acmesanitary.com.hk

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	QEST (USA) 13mm plastic angle valve with riser pipe 1/2" Female threaded for sea water use	Illustration/ Drawing
Model	QV302 (Angle Valve) QBA12 (1/2" Riser Pipe)	
Material	Plastic	
Manufacturer	QEST (USA)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

Note:

The color of the supply pipe may be varied without the prior notice

** All information of the above is for the reference only. No prior notice is made if any changes.*

本署檔號 : (3) in WSD 3321/2020 T/J(1114/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 November 2020



**Approval of "QEST" Angle Valve
(General Acceptance No. C20201033F)**

Your letter ref. SL20200813-1 dated 13 August 2020 and subsequent clarification by email on 20 October 2020 refer.

Having considered the test report ref. J25511 issued on 10 August 2020 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zurn Industries LLC
Country of Origin: USA
Brand: QEST
Details of Fitting: 1/2" Plastic angle valve
Model: QV302
Body Markings: QEST
Expiry Date: 3 August 2025

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only