



Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong

Tel: 2388 7171 Fax: 2710 8012

Email: acme@acmesanitary.com.hk

Website: www.acmesanitary.com.hk

Since 1949

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

<p>Item Descriptions</p> <p>Outlet</p> <p>Dimensions</p> <p>Model</p> <p>Material / White</p> <p>Manufacturer</p> <p>Source</p> <p>Contact Tel/Fax</p> <p>E-mail</p> <p>Website</p>	<p>Star (Thailand) "Legend" Vitreous china 630mm long space saver, close-coupled, washdown p-trap toilet with large grip lever for the disabled; Operating force of flushing control less than 22N ; test report J24271 ; complied with Barrier Free Access 2008 ; 6.4 LPF in WELS Grade 1 & Grade 3; Registration No.: WC 20-0005 & WC 20-0012</p> <p>H.O. Trapway, 190 mm</p> <p>L630 x W505 x H768 mm</p> <p>S-2688 (Bowl) S-3304.3 (Cistern)</p> <p>Vitreous China / White</p> <p>Star (Thailand)</p> <p>Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung</p> <p>(852) 2388-7171 / (852) 2710-8012 acme@acmesanitary.com.hk www.acmesanitary.com.hk</p>	<p>Illustration/ Drawing</p> <p>TOP VIEW</p> <p>SIDE VIEW</p>
---	--	---

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

<p>Item Descriptions</p> <p>Model</p> <p>Brand</p> <p>Country of origin</p> <p>Finish</p> <p>Supplier</p> <p>Contact Tel/Fax</p> <p>E-mail</p> <p>Website</p>	<p>Kims (PRC) Plastic side inlet valve (model no. C-3134) and 2-part round syphon valve (model no. B05-505)</p> <p>4079SI**</p> <p>Kims</p> <p>PRC</p> <p>Plastic</p> <p>Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung</p> <p>(852) 2388-7171 / (852) 2710-8012 acme@acmesanitary.com.hk www.acmesanitary.com.hk</p>	<p style="text-align: center;">Illustration/ Drawing</p>
---	--	--

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.




自願參與用水效益標籤計劃 - 水廁
Voluntary Water Efficiency Labelling Scheme - Water Closets



茲證明
This is to certify that
Acme Sanitary Ware Co. Ltd.

將下列水廁在本計劃內註冊：
has registered the following water closet under this scheme :

牌 子 / Brand	: Star
型 號 / Model	: S-2688
種 類 / Category	: Water Closet Pan
原 產 地 / Country or Region Origin	: Thailand

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:  滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	: 1
全沖水量 <i>Water Flush Volume (Full)</i>	: 4.7 公升/沖廁 <i>litres/flush</i>
低沖水量 <i>Water Flush Volume (Reduced)</i>	: 3.1 公升/沖廁 <i>litres/flush</i>

簽發日期:
Date of Issue: 3 April 2020

 水務署
Water Supplies Department



水務署署長(張業駒代行)
for Director of Water Supplies

+ 上述水廁具額外節水功能，即：重用洗盥水作沖廁用途。
The above water closet is equipped with additional water saving feature, that is: re-use the water collected from wash basin for flushing purpose.

註冊號碼 (Registration No.): WC 20-0012



自願參與用水效益標籤計劃 - 水廁
Voluntary Water Efficiency Labelling Scheme - Water Closets



茲證明

This is to certify that

Acme Sanitary Ware Co. Ltd.

將下列水廁在本計劃內註冊：

has registered the following water closet under this scheme :

牌子 / Brand	:	Star + Kims
型號 / Model	:	S-3304.3 + B05-505
種類 / Category	:	Water Closet Cistern
原產地 / Country or Region Origin	:	Thailand (WC Cistern) China (Flushing Valve)

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:	滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	3
全沖水量 <i>Water Flush Volume (Full)</i>	:	6.4 公升/沖廁 <i>litres/flush</i>
低沖水量 <i>Water Flush Volume (Reduced)</i>	:	Not specified 公升/沖廁 <i>litres/flush</i>

簽發日期:
Date of Issue: 29 April 2020



水務署署長(張業駒代行)
for Director of Water Supplies

+ 上述水廁具額外節水功能，即：重用洗盥水作沖廁用途。
The above water closet is equipped with additional water saving feature, that is, re-use the water collected from wash basin for flushing purpose.



水務署
Water Supplies Department



總行：香港灣仔道七號入境事務大樓 48 樓
Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號
Our ref.
來函檔號
Your ref.

1/2024 T/J(33/2024)

電話
Tel. :
傳真
Fax. : 2824 0578

19 March 2024



Dear Sir,

**Approval of "KIMS" Float Operated Valve
(General Acceptance No. C20240189F)**

Your E-Application [file-id: ETJ-GA-20240103-197] dated 10 January 2024 and subsequent submissions received by this department up to 26 February 2024 refer.

Having considered the test report ref. J29493 issued on 3 January 2024 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Dongguan Xin Tian Plastic Products Co Ltd

Country of Origin: the Mainland of China

Brand: Kims

Details of Fitting: 1/2" Plastic float operated valve

Model: C-3134

Body Markings:



Expiry Date: 14 December 2028

Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing systems.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



水務署
Water Supplies Department

總部 Headquarters

上打道七號入境事務大樓 48 樓
7 Gloucester Road, Wan Chai, Hong Kong



本署檔
Our ref.
來函檔號
Your ref.

21/2021 T/J(312/2021)

電話 :
Tel.
傳真 : 2824 0578
Fax.

22 March 2021



**Approval of “KIMS” Flush Valve
(General Acceptance No. C20210297F)**

Your letter ref. KS-11640 dated 6 February 2021 refers.

Having considered the test report ref. J25896 issued on 2 February 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Dongguan Xin Tian Plastic Products Co Ltd
Country of Origin: the Mainland of China
Brand: Kims
Details of Fitting: 1½" Plastic single flush valve
Model: B05-505
Body Markings: 
Expiry Date: 14 January 2026



Proviso: As the fitting has not been tested for use in contact with water intended for human consumption, the fitting can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The fitting should be used within the range of working pressures specified by the manufacturer." AND

"The installed fitting should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in flushing water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Nutek Systems

Nutek Systems (HK) Limited, Unit B, 13/F, Block A, Universal Industrial Centre, 23-25 Shan Mei Street, FO TAN, N.T., HONG KONG
Tel: +852 2605 5736 Fax: +852 2692 0798 info@nuteksystems.com www.nuteksystems.com

Test Report

TITLE : Testing of Flushing Control
 REFERENCE NO. : J 24271
 DESCRIPTION OF SAMPLE¹ : 'Marvel' tank with disabled lever
 SAMPLE SUBMITTED BY¹ : Acme Sanitary Ware Co., Ltd.
 1/F, Acme Building,
 22-28 Nanking Street
 Yau Ma Tei, Kowloon, Hong Kong
 MANUFACTURER¹ : Star
 BRAND¹ : Star
 COUNTRY OF ORIGIN¹ : Thailand
 MODEL¹ : S-3304.3
 BODY MARKINGS : 
 PERIOD OF TESTS : 14 Apr., 2019

¹ – Information provided by client

RESULTS: (apply only to the sample tested)

SUMMARY OF RESULTS

Test	Remark
1 Operating force of flushing control	C

1. OPERATING FORCE OF FLUSHING CONTROL BFA 2008 Cl. 50

Variable	Unit	Measured	Required	Remark
Operating Force	Newton	20	≤ 22	C
		20		C
		21		C
Overall result				C

Date: 10 May, 2019 Authorized signature: _____

NG DICK TH
(Test Engineer)



Nutek Systems is a testing agency,
accepted by the Water Supplies
Department, for testing water supply
fittings.