



Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong

Tel: 2388 7171 Fax: 2710 8012










Email: acme@acmesanitary.com.hk

Website: www.acmesanitary.com.hk

Since 1949

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Star (Thailand) "Junior Curve" Vitreous china wall hung washbasin with single hole & overflow; BSEN 14688:2006; capable of carrying a static load of 150kg; test report J26109	Illustration/ Drawing
Dimensions	L450 x W320 x H145 mm	    
Model	S-4408	
Material/Colour	Vitreous China / White	
Manufacturer	Star (Thailand)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	
<p>The curved designed of CURVE is suitable for a luxurious room but still needs gentleness for relaxation.</p> <p>With the curve-rounded and sweet design,the wall-hung CURVE is compatible with all standard sanitary wares,compact,space saving,able to place in a corner easily,suitable for a single room,dormitory,and etc.</p>		
  		
		

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong

Tel: 2388 7171 Fax: 2710 8012

Email: acme@acmesanitary.com.hk


Website: www.acmesanitary.com.hk

Since 1949







PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Dimensions



Installation Menu





Test Report

TITLE : Testing of Wash Basin
REPORT NO : J 26109
DESCRIPTION OF SAMPLE¹ : "Junior Curve" Vitreous china wall hung washbasin
SAMPLE SUBMITTED BY¹ : Acme Sanitary Ware Co., Ltd.
1/F, Acme Building,
22-28 Nanking Street
Yau Ma Tei, Kowloon
Hong Kong
BODY MARKINGS : /
BRAND¹ : Star (Thailand)
MODEL¹ : S-4408
MANUFACTURER¹ : Star Sanitarywares (Thailand) Co., Ltd.
COUNTRY OF ORIGIN¹ : Thailand
METHOD OF TESTS : BS EN 14688: 2006 & BFA 2008
PERIOD OF TESTS : 17 Mar., 2021

¹ – Information provided by client

RESULTS: (apply only to the sample tested)

SUMMARY OF RESULTS

Test	Remark
I Load resistance	C



REPORT NO.: J 26109

1. LOAD RESISTANCE
BS EN 14688: 2006 Cl. 5.2

Variable	Unit	Sample	Requirement	Remark
Test load	kN	1.50	1.50 ± 0.01	C
Duration	h	1	1	C
Crack / Broken / Permanent distortion	/	No	No	C
Overall result				C

Remark :

The sample also complies with BFA 2008 Cl. 53

Date: 01 Apr., 2021

Authorized signature:

Lam Kwai Wah, Terry
(Operations Manager)

Nutek Systems is a testing agency,
accepted by the Water Supplies
Department, for testing water supply
fittings.