



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

<p>Item Descriptions</p> <p>Dimensions</p> <p>Model</p> <p>Material</p> <p>Country of Origin Manufacturer</p> <p>Supplier</p> <p>Contact Tel/Fax E-mail Website</p>	<p>GROHE (Germany) "BauEdge" Chrome plated single-lever basin mixer <b>S-Size</b>; nominated flow rate <b>5 L/min</b> in WELS <b>Grade 1</b>; Registration No. TM 23-0002</p> <p>L91 x W45 x H150 mm</p> <p>23330000</p> <p>Chrome Plated</p> <p>Thailand GROHE Limited</p> <p>Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen</p> <p>(852) 2388-7171 / (852) 2710-8012 acme@acmesanitary.com.hk www.acmesanitary.com.hk</p>	<p>Illustration/ Drawing</p>  <p>The technical drawing shows the following dimensions: Total height 180mm, spout height 150mm, spout diameter Ø45mm, spout angle 20°, spout width 90mm, mounting hole diameter Ø34mm, mounting hole offset max.30mm, total height to base 395mm, base width 91mm, and connection thread G<sup>3</sup>/<sub>8</sub>. A side view shows a 50° angle for the base. A Water Efficiency Label (WELS) is shown with a Grade 1 rating.</p>
<p><b>"BauEdge"</b> <b>Basin mixer 1/2" S-Size</b></p> <p><b>Product Descriptions</b></p> <ul style="list-style-type: none"> <li>• monobloc installation</li> <li>• metal lever</li> <li>• GROHE Long-Life 28 mm ceramic cartridge</li> <li>• GROHE Long-Life Shine durable sparkling sheen</li> <li>• GROHE Water Saving mousseur 5.7 l/min</li> <li>• rapid installation system</li> <li>• smooth body</li> <li>• flexible connection hoses</li> </ul>		

Note:

\* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.): TM 23-0002



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps




茲證明  
This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌子 / Brand	:	Grohe
型號 / Model	:	23330XXX + 407761040
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	Thailand (Mixer) Germany (Flow Controller)

XXX – denotes the code of colour

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	5.0	公升/分鐘 <i>litres/minute</i>

簽發日期: 13 January 2023  
Date of Issue:

 水務署  
Water Supplies Department



水務署署長(林麗恒代行)  
for Director of Water Supplies



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔士打道七號入境事務大樓 48 樓

Tower, 7 Gloucester Road, Wan Chai, Hong Kong



本署檔號  
Our ref.  
來函檔號  
Your ref.

2022 T/J(725/2022)

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

5 September 2022



**Approval of "GROHE" Basin Mixer  
(General Acceptance No. C20220829)**

Your letter ref. WRC/2745 dated 13 June 2022 and subsequent submissions received by this department up to 15 August 2022 refer.

Having considered the test report ref. J27590Ar1 issued on 29 July 2022 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Grohe AG

**Country of Origin:** Thailand

**Brand:** Grohe

**Details of Fitting:** 3/8" Single lever basin mixer

**Model:** 23330XXX  
(where "XXX" denotes the code of colour)

**Body Markings:**

**Expiry Date:** 25 January 2027.



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only