

Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong Tel: 2388 7171 Fax: 2710 8012 Email: acme@acmesanitarv.com.hk Since 1949 Website: www.acmesanitary.com.hk



PROJECT	REF	REV	ITEM CODE	
LOCATION	DATE		PAGE	

SANITARY WARE SPECIFICATION SHEET

GROHE (Thailand) "BauEdge" Single-lever Item Descriptions basin mixer 1/2" M-Size; nominated flow

> rate 4.9 L/min in WELS Grade 1; Registration No. TM 22-0298

L106 x W45 x H191 mm Dimensions

Model 23758001

Finish Chrome Plated

Country of origin Thailand

Manufacturer **GROHE Limited**

Supplier Acme Sanitary Ware Co. Ltd

Mr. Eric Wong/ Mr. Don Yuen


Contact Tel/Fax (852) 2388-7171 / (852) 2710-8012

E-mail acme@acmesanitary.com.hk Website www.acmesanitary.com.hk

"BauEdge"

Basin mixer 1/2 // M-Size

- · monobloc installation
- metal lever
- GROHE Longlife 28 mm ceramic cartridge
- · with temperature limiter
- · GROHE StarLight chrome finish
- · **GROHE Zero** isolated inner water ways lead and nickel free within the tap
- **GROHE EcoJoy** mousseur 5.7 l/min
- rapid installation system
- plastic pop-up waste set 1 1/4"
- flexible connection hoses
- professional edition



Illustration/ Drawing



^{*} All information of the above is for the reference only. No prior notice is made if any changes.



自願參與用水效益標籤計劃 - 水龍頭 Voluntary Water Efficiency Labelling Scheme - Water Taps





茲證明 This is to certify that

將下列水龍頭在本計劃內註冊: has registered the following water tap under this scheme:

牌 子 / Brand

Grohe

型 號 / Model

: 23758XX1 + 407761040

種 類 / Type

: Mixing

原產地 / Country or Region Origin

: Thailand (Mixer)

Germany (Flow Controller)

XX - denotes the code of colour

在用水效益標籤上展示的標誌

Symbolic Presentation on the Water Efficiency Label

滴水點

Water droplet(s)

用水效益级别

Water Efficiency Grade

1

4.9

.

公升/分鐘 litres/minute

耗水量 Waler

Water Consumption

簽發日期:

26 November 2021

Date of Issue:

\$5

水務署 Water Supplies Department



水務署署長(尤孝賢代行) for Director of Water Supplies



來函檔號

Your ref.

水務署 Water Supplies Department

總部 Headquarters

打道七號入境事務大樓 48 樓

Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 /2021 T/J(970/2021) Our ref.

Tel.

傳真 Fax

2824 0578

23 July 2021



Approval of "GROHE" Basin Mixer (General Acceptance No. C20210799)

Your letter ref. WRC/2582 dated 21 June 2021 refers.

Having considered the test report ref. J26529A issued on 4 June 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Grohe AG

Country of Origin: Thailand

Brand: Grohe

Details of Fitting: 3/8" Single lever basin mixer

Model: 23758XX1

GROHE

(where "XX" denote the code of colour)

Expiry Date:

Body Markings:

11 May 2026





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue ME/MC] - with soft copy only