




PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Welson (PRC) Chromium plated gunmetal angle stop valve 1/2" x 3/8" for flushing water system
Model	2728GM
Material/ Finish	Chromium Plated Gunmetal
Manufacturer	Welson (PRC)
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Illustration/ Drawing



A multi turn screw down pattern angle stop valve for flushing water application

- Casted one-piece gunmetal valve body provides durability and long-lasting performance
- Heavy duty body construction with chromium plated finishing
- For sea water/flushing water systems in accessible area
- Excellent corrosion resistance performance when servicing seawater application
- Water flow controlled by stem
- Extend inlet connecting length with C.P. gunmetal nipple
- Thread end outlet for connection with flexible hose
- Compression outlet for easy connect with WC using lavatory riser PEX pipe
- Include Clear Plastic Valve Case


Valve Manufacturing / Standards

2728GM Angle Stop Valve
 Inlet : 1/2" BSP female
 Outlet : 3/8" BSP male (10.5φ compression nut)

Flow Rate : 16.5L/min @ .5Bar
 24.3L/min @ 1Bar
 29.5L/min @ 1.5Bar
 36.4L/min @ 2Bar
 40.2L/min @ 2.5Bar
 43.1L/min @ 3Bar

Valve Component

No.	Description
1	Body
2	Bonnet
3	NBR Bonnet Packing
4	Nylon Stem
5	NBR Washer
6	Compression Nut
7	Handle



Valve Working Condition

Working Pressure : 10 Bar Max
 Working Temperature : Up to 80°C

Valve Test / Standards

Hydraulic pressure test : Up to 16 Bar (BS EN 200:2008)
 Hydraulic Resistance test : Up to 25 Bar (BS EN 200:2008)

* All information of the above is for the reference only. No prior notice is made if any changes.



水務署
Water Supplies Department



號入境事務大樓 48 樓
Level 48, Gloucester Road, Wan Chai, Hong Kong

本署檔號
Our ref. : (2) in WSD 3321/2021 T/J(108/2021)
來函檔號
Your ref. :


電話
Tel. :
傳真
Fax. : 2824 0578

26 February 2021

Approval of "WELSON" Angle Valve (General Acceptance No. C20210165F)

Your letter ref. WEL-2728GM-12292020AP dated 29 December 2020 refers.

Having considered the test report ref. 204659PC200249(1) issued on 28 December 2020 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Welson Metal & Sanitary Ware MFY
Country of Origin: the Mainland of China
Brand: Welson
Details of Fitting: 1/2" Copper alloy angle valve
Model: 2728GM
Body Markings: WELSON 2728GM 
Expiry Date: 7 December 2025



Proviso: The fitting can only be used in flushing water plumbing systems and fresh water fire services systems.

This Authority hereby permits the use of the above fitting in flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only