



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Welson (PRC) Chrome plated brass angle valve 1/2" x 3/8"
Model	2729
Material/ Finish	Brass / Chrome Plated
Manufacturer	Welson (PRC)
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Illustration/ Drawing



**Specifications**


Model No.	: 2729
Inlet	: 1/2" BSP Male
Outlet	: 3/8" BSP Male
Construction	: Chrome Plated Brass
Working Pressure	: 0.5 ~ 10 bar
Test Pressure	: 20 bar
Comply with	: BS1010

**Approval**

Approval	: Office of Hong Kong Water Supplies Department
Reference	: (4) in WSD 3321/2021 T/J(113/2021)
Acceptance Reference No.	: C20210360
Expiry Date	: 7 December 2025

**Material Construction**

Description / Material	
Body	/ Brass to BS1400 DCB3
Piston	/ Brass to BS1400 DCB3
Washer	/ H.G.S.N. Rubber
O Ring	/ H.G.S.N. Rubber



Note:

\* All information of the above is for the reference only. No prior notice is made if any changes.



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile      2824 0578

檔號  
Reference



2025 T/J(1048/2025)

19 December 2025



**Approval of “WELSON” Angle Valve  
(General Acceptance No. ZC20250971)**

Your WEL-2729-26092025AP dated 26 September 2025 and subsequent submission received by this department on 21 November 2025 refer.

Having considered the test report ref. 252562PC250839 issued on 11 September 2025 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

- Name of Manufacturer:** FS Welson Metal Manufacturing Company Limited
- Country of Origin:** Chinese Mainland
- Brand:** Welson
- Details of Fitting:** 1/2" Copper alloy angle valve
- Model:** 2729
- Body Markings:** WELSON
- Expiry Date:** 18 December 2030



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.    WSD 3321/1/82 ] - without catalogue  
         ME/MC        ] - with soft copy only