



Acme Sanitary Ware Co. Ltd.

1/F, Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong
Tel: 2388 7171 Fax: 2710 8012
Email: acme@acmesanitary.com.hk
Website: www.acmesanitary.com.hk

WELSON®

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Welson (PRC) Chrome plated brass angle valve 1/2" x 3/8"	Illustration/ Drawing
Model	2729	
Material/ Finish	Brass / Chrome Plated	
Manufacturer	Welson (PRC)	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	



Specifications


Model No.	: 2729
Inlet	: 1/2" BSP Male
Outlet	: 3/8" BSP Male
Construction	: Chrome Plated Brass
Working Pressure	: 0.5 ~ 10 bar
Test Pressure	: 20 bar
Comply with	: BS1010

Approval

Approval	: Office of Hong Kong Water Supplies Department
Reference	: (4) in WSD 3321/2021 T/J(113/2021)
Acceptance Reference No.	: C20210360
Expiry Date	: 7 December 2025

Material Construction

Description / Material	
Body	/ Brass to BS1400 DCB3
Piston	/ Brass to BS1400 DCB3
Washer	/ H.G.S.N. Rubber
O Ring	/ H.G.S.N. Rubber



Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



Department

七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(113/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 April 2021

Approval of "WELSON" Angle Valve (General Acceptance No. C20210360)

Your letters ref. WEL-2729-12292020AP and WEL-2729-15032021AP-C1 dated 29 December 2020 and 15 March 2021 respectively refer.

Having considered the test report ref. 204659PC200249(2)A issued on 11 March 2021 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Welson Metal & Sanitary Ware MFY

Country of Origin: the Mainland of China

Brand: Welson

Details of Fitting: 1/2" Copper alloy angle valve

Model: 2729

Body Markings: WELSON

Expiry Date: 7 December 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only