






PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

## SANITARY WARE SPECIFICATION SHEET

Item Descriptions	GROHE (Germany) "Eurosmart Cosmopolitan E" Infra-red electronic wall mounted basin mixer with mixing device, adjustable temperature limiter and concealed mounting box; nominated flow rate <b>4.4 L/min</b> in WELS <b>Grade 1</b> ; Registration No. TM 22-0055		Illustration/ Drawing 
Dimensions	L120 x W172 x H195 mm		
Model	36315000 (Basin Mixer) 36339001 (Mounting Box)		
Finish	Chrome Plated		
Manufacturer	GROHE Limited		
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen (852) 2388-7171 / (852) 2710-8012		
Contact Tel/Fax	acme@acmesanitary.com.hk		
E-mail	www.acmesanitary.com.hk		
Website			
<p><b>36315000 ( Basin Tap)</b> Infra-red electronic basin mixer with mixing device and adjustable temperature limiter with infrared sensor for bi-directional communication for monitoring, configuration and servicing with transformer 100-230 V AC, 50-60 Hz, 6 V DC laminar flow straightener 9 l/min chrome escutcheon chrome spout projection 170 mm 7 pre-set programs auto flush thermal disinfection cleaning mode additional functions and precise settings by remote control 36 407 set for final installation for concealed fitting box 36 339 001 CE approved noise classification 1 in accordance with DIN4109</p>		<p><b>36339001 (Mounting Box)</b> Eurosmart Cosmopolitan E Concealed mounting box with mixture wall installation suitable for IR-sets for final installation 2 stop valves housing with mixing device non-return valve connection housing for power supply suitable for 36 315 000, 36 412 000, 36 376 000 allows for waterproofing of wall construction surrounding the concealed body with sealing sleeve</p> 	

Note:

\* All information of the above is for the reference only. No prior notice is made if any changes.



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明  
This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌子 / Brand	:	Grohe
型號 / Model	:	36339001 + 36315XXX + 403655031
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	Germany (Mixer & Flow Controller)

XXX – denotes the code of colour

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:	 滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1 with additional merit*
耗水量 <i>Water Consumption</i>	:	4.4 公升/分鐘 <i>litres/minute</i>

\*with additional merit of "Automatic closing mechanism"

簽發日期: 25 March 2022  
Date of Issue:



水務署  
Water Supplies Department



水務署署長(林麗恒代行)  
for Director of Water Supplies



水務署  
Water Supplies Department



總部 Headquarters

灣仔告士打道七號入境事務大樓 48 樓

Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

WSD 3321/2021 T/J(1153/2021)

Our  
來函編號  
Your ref.

電話

Tel.

傳真

Fax.

: 2824 0578

17 November 2021



### Approval of "GROHE" Sensor Mixer (General Acceptance No. C20211265)

Your letters ref. WRC/2590 and C-WSD/0860 dated 21 July 2021 and 21 September 2021 respectively refer.

Having considered the test report ref. 210784PC210034B issued on 13 September 2021 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.


**Name of Manufacturer:** Grohe AG

**Country of Origin:** Germany

**Brand:** Grohe

**Details of Fitting:** 1/2" Wall mounted sensor basin mixer

**Model:** 36339001 + 36315XXX  
(where "XXX" denote the code of colour)

**Body Markings:** 

**Expiry Date:** 12 May 2026





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only