


PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

# SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Inax (Japan) Chrome plated thermostatic wall mounted sensor basin mixer; spout in 190mm long; AC Supply; built-in flow controller AC-360; nominated flow rate <b>2.3 L/min</b> in <b>WELS Grade 1</b> ; Registration No. TM 20-0104
Dimensions	Spout length : 190mm
Model	AMC150TCA-WP
Finish	Chrome Plated
Manufacturer	Inax (Japan)
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Detail specifications:

Detail specifications:  
 Wall Mounted Sensor Thermostatic Faucet  
 Spout length: 180 – 190mm  
 AC Operated (220V)  
 Water pressure: 0.05 MPa – 0.7.5 MPa

Dynamic flow pressure (kPa)	50	150	250	350	500
Flow rate (l/ min )	1.88	2.33	2.33	2.33	2.33

Illustration/ Drawing

**Note : New Code: FFIX8510-02050JBC0**

*\* All information of the above is for the reference only. No prior notice is made if any changes.*

註冊號碼 (Registration No.):

TM 20-0104



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明

This is to certify that

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌 子 / Brand	:	INAX
型 號 / Model	:	AMC150TCA-WP + AC-360
種 類 / Type	:	Mixing
原產地 / Country or Region Origin	:	China (Mixer & Flow Controller)

在用水效益標籤上展示的標誌

*Symbolic Presentation on the Water Efficiency Label*



滴水點

*Water droplet(s)*

用水效益級別

*Water Efficiency Grade*

:

1

with additional merit\*

耗水量

*Water Consumption*

:

2.3

公升/分鐘

*litres/minute*

\*with additional merit of "Automatic closing mechanism"

簽發日期:

*Date of Issue:*

18 June 2020



水務署

Water Supplies Department



水務署署長(張業駒代行)  
for Director of Water Supplies



水務署  
Water Supply Department



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/18 Pt.1 T/J(998)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

22 October 2018

### Approval of "INAX" Sensor Mixer (General Acceptance No. C20180694)

Your letter ref. WRC/1936 dated 24 August 2018 refers.

Having considered the test reports ref. J21683A and J21657r1 issued on 16 August 2018 and 20 April 2018 by Nutek Systems (HK) Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** INAX

**Country of Origin:** China

**Brand:** INAX

**Details of Fitting:** 1/2" Electronic sensor basin mixer with 1 no. of rubber hose

**Model:** AMC150TCA-WP

**Body Markings:** 

**Expiry Date:** 28 August 2022 (for mixer + hose)





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only