




PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			CODE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	EMCA (PRC) 1/2" Chrome plated self-closing tap with large esay push button with 1/2" x 1/2" x 350mm stainless steel flexible braid hose; nominated flow rate 1.6 L/min in WELS Grade 1 Registration No.TN 19-0067
Dimensions	L115 x W50 x H138 mm
Model	EM3040.100
Finish	Brass Chrome Plated
Manufacturer	EMCA (PRC)
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong / Mr. Don Yuen
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012
E-mail	acme@acmesanitary.com.hk
Website	www.acmesanitary.com.hk

Illustration/ Drawing



Dynamic flow pressure (kPa)	50	150	250	350	500
Flow rate (l/min)	1.38	1.55	1.63	1.70	1.75

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.

註冊號碼 (Registration No.):

TN 19-0067



自願參與用水效益標籤計劃 - 水龍頭
Voluntary Water Efficiency Labelling Scheme - Water Taps



茲證明
This is to certify that
Acme Sanitary Ware Co., Ltd.

將下列水龍頭在本計劃內註冊：
has registered the following water tap under this scheme :

- 牌子 / Brand : EMCA
- 型號 / Model : EM3040.100
- 種類 / Type : Non-mixing
- 原產地 / Country or Region Origin : China

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	with additional merit*
耗水量 <i>Water Consumption</i>	:	1.6	公升/分鐘 <i>litres/minute</i>

*with additional merit of "Automatic closing mechanism"

簽發日期：
Date of Issue: 22 May 2019

水務署
Water Supplies Department



水務署署長(張業駒代行)
for Director of Water Supplies



上打道七號入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1216)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

26 November 2018



Approval of "EMCA" Self Closing Tap (General Acceptance No. C20180802)

Your letters ref. L017/2018 and L019/2018 dated 30 October 2018 and 8 November 2018 respectively refer.

Having considered the test report ref. J23263A issued on 4 October 2018 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kaiping City Doyei Sanitary Ware Corporation

Country of Origin: the Mainland of China

Brand: EMCA

Details of Fitting: 1/2" Self closing tap

Model: EM3040.100

Body Markings: EMCA

Expiry Date: 16 September 2023



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless other specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Acme Sanitary Ware Co Ltd

Acme Building, 22-28 Nanking Street, Kowloon, Hong Kong


Tel: 2388 7171 Fax: 2710 8012

E-mail: acme@acmesanitary.com.hk

Website: www.acmesanitaryware.com.hk

PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	F1/2" x F1/2"x 350mm Stainless steel flexible hose, 350mm length (HKWA Approved)	Illustration/ Drawing 
Model	HL-SS-02-02-008-035	
Finish	Stainless Steel	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



Water Services Department

入境事務大樓 48 樓
Regatta Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/19 T/J(1002/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 November 2019



Dear Sir,

Approval of "HL" Flexible Hoses (General Acceptance No. B20190064)

Your letters ref. TFWC-2019-010, TFWC-2019-010R1 and TFWC-2019-010R dated 27 September 2019, 23 October 2019 and 25 October 2019 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kaiping City Hualing Hoses Co Ltd

Country of Origin: the Mainland of China

Brand: HL

Details of Fitting: Nylon and stainless steel braided flexible hose assemblies with EPDM inner hose and brass end connectors which incorporate EPDM washers and 'O'-rings. Maximum

working pressure 10.0 bar. Maximum working temperature 85°C

Model and Size:

HL-SS-XX-XX-XXX-XXX
HL-N-XX-XX-XXX-XXX

SS=Stainless Steel Braided Hose
N=Nylon Pull out Hose

1st & 2nd XX = Connection sizes:

01=F3/8

02=F1/2

03=F3/4 (only available on SS models)

04=F15*1 (only available on SS models)

05=M3/8 (only available on SS models)

06=M1/2 (only available on SS models)

07=M3/4 (only available on SS models)

08=M15

09=M12

10=M10

12=Pushfit (M) 11mm ID or (F) 11mm OD

1st XXX:

Hose size:

Nylon and stainless steel braided hoses:

006= DN6, 008= DN8

Stainless steel braided hoses only:

010= DN10, 014= DN14

2nd XXX:

Hose length:

15CM - 200CM

Body Markings:

Hualing, WRAS and date of manufacture (yyyy) on ferrule

WRAS Approval Number: 1909363

Installation Requirements: R001

Expiry Date: 30 September 2024

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only