





PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	EMCA (PRC) Ø32 x 600 x 600mm long stainless steel 304 L-shape grab bar in satin finish ; GB 175-2007 ; capable of carrying a static loading test 150kg ; test report J23743 ; complied with Barrier Free Access 2008	<p style="text-align: center;">Illustration/ Drawing </p> 
Dimensions	32 dia x 600 x 600 mm	
Model	EM7012.013	
Material	Stainless steel	
Manufacturer	EMCA (PRC)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

Note:
Loading test report : J23743 150kg loading test

** All information of the above is for the reference only. No prior notice is made if any changes.*



Test Report

TITLE : Loading test
OUR REFERENCE : J 23743
DESCRIPTION OF SAMPLE : Ø32 x 600 x 600 mm stainless steel L-shape grab bar
SAMPLE SUBMITTED BY : Acme Sanitary Ware Co., Ltd.
1/F, Acme Building, 22-28 Nanking Street
Yau Ma Tei, Kowloon, Hong Kong
BRAND : EMCA
COUNTRY OF ORIGIN : China
MODEL : EM7012.013
METHOD OF TESTS : Loading test
PERIOD OF TESTS : 03 Dec., 2018


RESULTS: (apply only to the sample tested)

1. LOADING TEST

The sample was installed onto a concrete wall in its normal application (cement to GB 175-2007). A test load was applied to the mid point of the sample which was then examined for any signs of damage.

ID	Weight/ downward load (kg)	Test duration (min)	Break/failure/ deflection/crack
Sample	150	30	Nil

Remark: Pass

Date: 07 Dec., 2018 Authorized signature: 

Nutek Systems is a testing agency, approved by the Water Authority and Government Supplies Department, for testing water supply fittings.

NG DICK TIK LUN
(Mechanical Engineer)