



PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

**SANITARY WARE SPECIFICATION SHEET**

Item Descriptions	EMCA (PRC) Ø32 x 750mm long stainless steel 304 hinged support rail in satin finish; BS12:1978 & BS882:1973 capable of carrying a <b>static loading test 150kg</b> ; test report J17176 ; complied with Barrier Free Access 2008	<p align="center">Illustration/ Drawing</p> <p align="center">304 Stainless Steel Expansion Screw (6pcs)</p>
Dimensions	32mm dia x 750mm long	
Model	EM7020.013	
Finish	Stainless Steel	
Manufacturer	EMCA (PRC)	
Supplier	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Wilson Hung	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

ACME Sanitary Ware Co. Ltd.

**先托高，然後拉向下**  
**FIRST LIFT UP, THEN PULL DOWN**

配件：爆炸螺丝M8

Note:

\* All information of the above is for the reference only. No prior notice is made if any changes.



# NUTEK SYSTEMS, LTD.

Unit B, 13/F, Block A, Universal Ind. Ctr., 23-25 Shan Mei Street, Fo Tan, Shatin, N.T., Hong Kong.  
Tel: (852) 2605 5736 Fax: (852) 2692 0798 E-mail: nutek@nuteksystems.com

TITLE : Testing of rail  
OUR REFERENCE : J 17176  
DESCRIPTION OF SAMPLE : Ø32mm x 750mm Stainless steel swing up grab bar  
SAMPLE SUBMITTED BY : Acme Sanitary Ware Co. Ltd.  
1/F., Acme Building, 22 Nanking Street, Kowloon, Hong Kong  
BRAND : EMCA  
MODEL : EM7020.013  
COUNTRY OF ORIGIN : China  
TEST REQUIRED : Loading test  
PERIOD OF TESTS : 6<sup>th</sup> August 2013

**RESULTS** : - (apply only to the sample tested)

## LOAD TEST


The grab rail sample was installed onto a concrete wall made of concrete mix grade 30D10 (cement to BS12: 1978 and Aggregate to BS882: 1973).

A test load was applied vertically to the mid point of the rail which was then examined for any signs of damage.

	Test load (kg)	Duration (minute)	Visual damage (e.g. breakage, deformation, etc.)	Remark
Sample	150	5	No visual damage	Pass

Date : 26 Nov 2013 Authorized signature : \_\_\_\_\_

Nutek Systems is a testing agency,  
approved by the Water Authority and  
Government Supplies Department, for  
testing water supply fittings.

  
Sunny K.S. Wong

( Director )