




PROJECT		REF		REV	ITEM CODE	
LOCATION		DATE			PAGE	

SANITARY WARE SPECIFICATION SHEET

Item Descriptions	Nobili (Italy) "Live" Single lever sink mixer, swivel spout, anti-limestone aerator M 24 x 1, ø 3/8" stainless steel flexible hoses.	<p>Illustration/ Drawing</p>
Standard	QAVR (Italy)  SICURAMENTE MADE IN ITALY	
Dimensions	L318 x W118 x H310 mm	
Model	LV00113 CR	
Finish	Chrome Plated	
Manufacturer	Nobili (Italy)	
Source	Acme Sanitary Ware Co. Ltd Mr. Eric Wong/ Mr. Don Yuen	
Contact Tel/Fax	(852) 2388-7171 / (852) 2710-8012	
E-mail	acme@acmesanitary.com.hk	
Website	www.acmesanitary.com.hk	

SPECIFICATIONS

- Single control
- Chrome
- 360° swivel spout
- Anti limescale aerator M 24 x 1
- ø 3/8" stainless steel flexible pipe
- 50% two step cartridge for water saving



Note:

* All information of the above is for the reference only. No prior notice is made if any changes.



Department

香港入境事務大樓 48 樓
48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(220/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 May 2020



Approval of "NOBILI" Sink Mixer (General Acceptance No. C20200336)

Your letter ref. KHL-Let-20200304 dated 4 March 2020 and subsequent submissions received by this department up to 29 April 2020 refer.

Having considered the test report ref. 196549PC190364A issued on 24 April 2020 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.


Name of Manufacturer: Carlo Nobili SpA Rubinetterie

Country of Origin: Italy

Brand: Nobili

Details of Fitting: 3/8" Single lever sink mixer

Model: LV00113XX
(where "XX" denotes different colour finishes)

Body Markings: **NOBILI** 

Expiry Date: 14 January 2025



This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only